



## Errata

# NFPA 25

## Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems

2017 Edition

**Reference:** Table 9.1.1.2 and Table 13.1.1.2

**Errata No.:** 25-17-2

The Technical Committee on Inspection, Testing, and Maintenance of Water-Based Systems notes the following errors in the 2017 edition of NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*.

1. Correct the “frequency” in the tables as indicated below:

---

**Table 9.1.1.2 Summary of Water Storage Tank Inspection, Testing, and Maintenance**

---

Item	Frequency	Reference
<b>Inspection</b>		
Air pressure—tanks that have their air pressure source supervised	Quarterly	9.2.2.1
...		
<b>Test</b>		
High temperature limit switches	Monthly*	9.3.4
...		
Water level alarms	<del>Semiannually</del> <u>Annually</u>	9.3.5
...		
Water Level	—	9.4.2

---

**Table 13.1.1.2 Summary of Valves, Valve Components, and Trim Inspection, Testing, and Maintenance**

<b>Item</b>	<b>Frequency</b>	<b>Reference</b>
<b>Inspection</b>		
<i>Backflow Prevention Assemblies</i>		
Reduced pressure	Weekly/Monthly	13.7.1
...		
<b>Testing</b>		
...		
Low air pressure alarm	<del>Quarterly</del> <u>Annually</u>	13.4.5.2.6
...		
<i>Deluge Valves</i>	Annually	13.4.4.3

Issue Date: June 18, 2019

**(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))**

Copyright © 2019 All Rights Reserved  
 NATIONAL FIRE PROTECTION ASSOCIATION