



Errata

NFPA 72[®]

National Fire Alarm and Signaling Code[®]

2019 Edition

Reference: 18.4.2.3

Errata No.: 72-19-2

The Technical Committee on Notification Appliances for Fire Alarm and Signaling Systems and the Correlating Committee on Signaling Systems for the Protection of Life and Property note the following errors in the 2019 edition of NFPA 72, *National Fire Alarm and Signaling Code*.

1. Add paragraph 18.4.2.3 which was inadvertently omitted, also renumber subsequent paragraphs and Annex accordingly as follows:

18.4.2.2 A single-stroke bell or chime sounded at “on” intervals lasting 1 second \pm 10 percent, with a 2-second \pm 10 percent “off” interval after each third “on” stroke, shall be permitted.

18.4.2.3 The signal shall be repeated for a period appropriate for the purposes of evacuation of the building, but for not less than 180 seconds.

18.4.2.23.1 The minimum repetition time shall be permitted to be manually interrupted.

18.4.2.23.2 The minimum repetition time shall be permitted to be automatically interrupted for the transmission of mass notification messages in accordance with Chapter 24.

18.4.2.34* The standard evacuation signal shall be synchronized within a notification zone.

A.18.4.2.34 Coordination or synchronization of the audible signal within a notification zone ...

Issue Date: June 18, 2019

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION