



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2020 Edition

Reference: 725.121(C)
TIA 20-1
(SC 19-8-19 / TIA Log #1438)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise 725.121(C) to read as follows:*

725.121(C) Marking. The power sources for limited power circuits in 725.121(A)(3), limited power circuits for listed audio/video equipment, listed information technology equipment, listed communications equipment, and listed industrial equipment in 725.121(A)(4) shall have a label indicating the maximum voltage and maximum current or maximum voltage and nominal current output per conductor for each connection point on the power source. Where multiple connection points have the same rating, a single label shall be permitted to be used. For equipment with a rated current per conductor less than 0.3 amperes, the effective date shall be January 1, 2021.

Issue Date: August 6, 2019

Effective Date: August 26, 2019

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION