



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2020 Edition

Reference: Table 430.252

TIA 20-7

(SC 19-8-26 / TIA Log #1462)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Delete Table 430.252 in its entirety:

~~Table 430.252 Minimum Size Equipment Grounding Conductors for Grounding Motor Circuits and Equipment~~

Rating or Setting of Branch Circuit Short-Circuit and Ground-Fault Protective Device in Circuit Ahead of Equipment, Conduit, etc., Not Exceeding (Amperes)	Size (AWG or kcmil)	
	Copper	Aluminum or Copper-Clad Aluminum*
15	14	12
20	12	10
60	10	8
100	8	6
200	6	4
300	4	2
400	3	1
500	2	1/0
600	1	2/0
800	1/0	3/0
1000	2/0	4/0
1200	3/0	250
1600	4/0	350
2000	250	400
2500	350	600
3000	400	600
4000	500	750
5000	700	1200
6000	800	1200

~~Note: Where necessary to comply with 250.4(A)(5) or (B)(4), the equipment grounding conductor shall be sized larger than given in this table.~~

~~*See installation restrictions in 250.120.~~

Issue Date: August 6, 2019

Effective Date: August 26, 2019

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION