



Errata

NFPA 70[®]

National Electrical Code[®]

2020 Edition

Reference: 700.16(B)

Errata No.: 70-20-1

The National Electrical Code-Making Panel 13 and the Correlating Committee on National Electrical Code note the following error in the 2020 edition of *NFPA 70, National Electrical Code*.

1. Update the reference in 700.16(B) to read as follows:

700.16(B) System Reliability. Emergency lighting systems shall be designed and installed so that the failure of any illumination source cannot leave in total darkness any space that requires emergency illumination. Control devices in the emergency lighting system shall be listed for use in emergency systems. Listed unit equipment in accordance with 700.12(~~F~~)(I) shall be considered as meeting the provisions of this section.

Issue Date: October 10, 2019

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2019 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION