

	A	B	C	D	E	F	G	H
1	Code	Proposal No.	Description Topic	Work Group Comments	Work Group Vote	CAH Action	PCH Action	Online Vote
2	IEBC	ADM2-19	Revision to what constitutes a change of occupancy	Appears to increase the chances that minor alterations could trigger a full code upgrade. Would permit a single term to have two different definitions in different codes.	Oppose	Disapproved	Sustained	
3		ADM8-19	Application of code in e'xg bldgs.	Concise and reasonable	Support	Approved	Sustained	
4		EB5-19	Adds accessibility req'mts	Equalizes accessibility req'mts no matter which compliance method is chosen	Support	Disapproved	Sustained	
5		EB12-19	Adds req'mts when ext facades are replaced	Most reasonable of several competing proposals	Support	Approved	Sustained	
6		EB13-19	Req sprinklers in high rises when ext façade is replaced		No Comment	Disapproved	Sustained	
7		EB20-19	Adds accessibility req'mts		No Comment	Approved	Sustained	
8		EB22-19	Adds accessibility req'mts		No Comment	Approved	Sustained	
9		EB35-19	Modifies accessibility req'mts for seating in dining halls	Promotes design creativity	No Comment	Disapproved	Sustained	
10		EB38-19	Calculate occupancy load based on space capacity	Allows over-occupancy to more easily occur	No Comment	Disapproved	Sustained	
11		EB42-19	Where guardrails are required	How does this apply to stages? Pools? Bleachers? Differs from OSHA regs.	No Comment	Disapproved	Sustained	
12		EB51-19	Adds classroom acoustics criterion for hearing disabilities	Will have large cost implications. Too many exceptions listed, confusing	No Comment	Approved	Sustained	
13		EB54-19	Adds req'mts for rooftop supported mech equip		Support	Approved	Consent Agenda	
14		EB104-19	Provide an exception for stairways that are an exg penetration	Provides designers options for compliance	Support	Disapproved	Sustained	
15		EB120-19	One of several addressing compartmentalization	Requires better writing	No Comment	Approved	Sustained	
16		EB121-19	Compartmentalization	Written better	Support	Disapproved	Sustained	
17		EB123-19	Compartmentalization		Oppose	Disapproved	Sustained	

	A	B	C	D	E	F	G	H
18		EB125-19	Establishes categories for corridor walls	Provides more design options	Support	Approved	Sustained	
19		EB126-19	Establishes categories for HVAC systems		Oppose	Disapproved	Sustained	
20		EB129-19	Establishes separations between occupancy groups		Oppose	Disapproved	Sustained	
21		EB134-19	Establishes construction req'mts for exg bldgs		Support	Disapproved	Sustained	
22	IECC	CE34-19	One of several revising calculation of U-factor		Support	Disapproved	Sustained	
23		CE32-19	Revisions to std ref design		No Comment	Disapproved	Sustained	
24		CE34-19	Revisions to U-factor	Would only permit factory made and tested units, eliminate site-built units	Oppose	Disapproved	Sustained	
25		CE40-19	R value marking of insulation		No Comment	Approved	Sustained	
26		CE44-19	Exception for sleeping units in R-2		No Comment	Disapproved	Overtaken	
27		CE47-19	Defines and makes req'mts for zero-energy	Provision should be in IGCC not IECC	Oppose	Disapproved	Sustained	
28		CE49-19	Modifies performance based compliance path		Oppose	Disapproved	Sustained	
29		CE50-19	One of several dealing w/ replacement fenestration		No Comment	Disapproved	Sustained	
30		CE52-19	Replacement fenestration		No Comment	Disapproved	Sustained	
31		CE53-19	Renewable energy cert	Doesn't account for solar blockage that may occur in the future	Oppose	Disapproved	Sustained	
32		CE55-19	Thermal envelope cert	How are R-values certified?	Oppose	Approved	Overtaken	
33		CE56-19	Includes greenhouses under code	Greenhouses not built for human occupancy. Could interfere with research activities.	Oppose	Disapproved	Sustained	
34		CE57-19	Excludes greenhouses and small Utilities out-buildings	Bldgs under 100 SF are already exempt	No Comment	Disapproved	Sustained	
35		CE84-19	Revisions to U-factor		No Comment	Approved	Sustained	
36		CE85-19	Revisions to U-factor		No Comment	Approved	Sustained	
37		CE86-19	Revisions to U-factor		No Comment	Disapproved	Sustained	

	A	B	C	D	E	F	G	H
38		CE87-19	Revisions to U-factor		No Comment	Approved	Sustained	
39		CE88-19	Revisions to U-factor		Oppose	Disapproved	Sustained	
40		CE111-19	Adds FDD Req'mt	Smart investment, but large expense, but only affects bldgs > 100,000 SF	Oppose	Approved	Sustained	
41		CE113-19	Provides HVAC performance req'mts		Support	Approved	Sustained	
42		CE120-19	Auto HVAC start/stop	Object to loss of local on-site control	Oppose	Approved	Sustained	
43		CE129-19	Parking Garage ventilation control		No Comment	Approved	Sustained	
44		CE130-19	Demand control ventilation		No Comment	Disapproved	Sustained	
45		CE138-19	Deletion of FEC		No Comment	Disapproved	Sustained	
46		CE139-19	FEI		No Comment	Approved	Sustained	
47		CE142-19	Tower flow turn-down		Support	Disapproved	Sustained	
48		CE144-19	One of several regarding walk-in coolers and freezers		No Comment	Approved	Sustained	
49		CE145-19	Walk-in coolers and freezers		Support	Disapproved	Sustained	
50		CE146-19	Walk-in coolers and freezers		No Comment	Approved	Sustained	
51		CE147-19	Walk-in coolers and freezers		No Comment	Disapproved	Sustained	
52		CE148-19	Walk-in coolers and freezers		No Comment	Disapproved	Sustained	
53		CE149-19	Walk-in coolers and freezers		No Comment	Approved	Sustained	
54		CE150-19	Provide physical protection for pipe insulation		Oppose	Disapproved	Sustained	
55		CE157-19	Pipe insulation		No Comment	Disapproved	Sustained	
56		CE215-19	Requires energy monitoring/metering	High first cost if not already in place. Metering energy does not equal saving energy	Oppose	Approved	Approved as modified	
57		CE260-19	HVAC acceptance testing	Worried that small insignificant systems would get included into expensive testing.	Oppose	Disapproved	Sustained	
58		CE263-19	Req'mts for PV systems		No Comment	Disapproved	Sustained	