



## Errata

# NFPA 13

## *Standard for the Installation of Sprinkler Systems*

### 2019 Edition

**Reference:** 9.5.3.2.2, Table 23.6.1

**Errata No:** 13-19-5

The Technical Committees on Sprinkler System Installation Criteria, Sprinkler System Discharge Criteria, and the Correlating Committee on Automatic Sprinkler Systems note the following errors in the 2019 edition of NFPA 13, *Standard for the Installation of Sprinkler Systems*.

*1. Add paragraph 9.5.3.2.2, which was inadvertently omitted from the document, and renumber subsequent paragraphs as follows:*

**9.5.3.2** Maximum Distance from Walls.

**9.5.3.2.1** The distance from sprinklers to walls shall not exceed one-half of the allowable maximum distance between sprinklers.

**9.5.3.2.2** The distance from the wall to the sprinkler shall be measured perpendicular to the wall.

**9.5.3.2.23** The distance from the wall to the sprinkler shall be measured to the wall behind furniture, such as wardrobes, cabinets, and trophy cases.

**9.5.3.2.34** The distance from the wall to the sprinkler shall be measured to the wall when sprinklers are spaced near windows and no additional floor space is created.

2. Remove the two asterisks (\*) that were inadvertently added to the line items below:

**Table 23.6.1 ESFR Protection of Rack Storage of Group A Plastic Commodities**

Storage Arrangement	Commodity	Maximum Storage Height		Maximum Ceiling/Roof Height		Nominal K-Factor	Orientation	Minimum Operating Pressure		In-Rack Sprinkler Requirements
		ft	m	ft	m			psi	bar	
...										
Single-double-, and multiple-row racks (no open-top containers)	Cartoned unexpanded	30	9.1	40	12	16.8 (240)	Pendent	52	3.6	
						22.4 (320)	Pendent*	40	2.7	
						25.2 (360)	Pendent*	25	1.7	
...										

Issue Date: March 10, 2020

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2020 All Rights Reserved  
 NATIONAL FIRE PROTECTION ASSOCIATION