



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2020 Edition

Reference: 800.100(B)(2) Informational Note and Informational Note Figure caption

TIA 20-9

(SC 20-4-13 / TIA Log #1479)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70, *National Electrical Code*, 2020 edition. The TIA was processed by the National Electrical Code Panel 16 and the NEC Correlating Committee, and was issued by the Standards Council on April 1, 2020, with an effective date of April 21, 2020.

1. Revise 800.100(B)(2) Informational Note and its associated Figure's caption to read as follows:

800.100(B)(2) ...

Informational Note: Informational Note Figure 800.100(B)(2) illustrates the connection of the bonding conductor in buildings or structures not equipped with an intersystem bonding termination or a terminal block providing access to the building grounding means.

Informational Note Figure 800.100(B)(2) Illustration of a Grounding Electrode Conductor and a Bonding Conductor in a Communications Installation.

Issue Date: April 1, 2020

Effective Date: April 21, 2020

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2020 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION