



Tentative Interim Amendment

NFPA® 13

Standard for the Installation of Sprinkler Systems

2019 Edition

Reference: Table 25.9.2.3.1
TIA 19-7
(SC 20-8-24 / TIA Log #1489)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2019 edition. The TIA was processed by the Technical Committee on Sprinkler System Discharge Criteria and the Correlating Committee on Automatic Sprinkler Systems, and was issued by the Standards Council on August 11, 2020, with an effective date of August 31, 2020.

1. *Revise the title of Table 25.9.2.3.1 to read as follows:*

Table 25.9.2.3.1 Multiple-Row Racks of ~~Nonencapsulated~~ Class I Through Class IV Commodities Stored Over 25 ft (7.6 m) in Height Protected by CMDA Sprinklers at Ceiling Level

Issue Date: August 11, 2020

Effective Date: August 31, 2020

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2020 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION