



Errata

NFPA 13

Standard for the Installation of Sprinkler Systems

2022 Edition

Reference: 1.6.2, Table 19.2.3.1.1 and 31.1.1

Errata No: 13-22-1

Note: Prior to the printing of NFPA 13 these errors were noted and incorporated into the standard at the time of issuance.

1. Update the cross reference in paragraph 1.6.2 to read as follows:

1.6.2 Hydraulic Symbols. The standard abbreviations in Table 1.6.2 shall not be used on the hydraulic calculation form discussed in Chapter ~~23~~28.

2. Update the heading for the second column in Table 19.2.3.1.1 to read as follows:

Table 19.2.3.1.1 Density/Area

Hazard	Density/Area [gpm/ft²/ft² (mm/min/m²)]
Light	0.1/1500 or 0.07/3000* (4.1/140 or 2.9/280)
Ordinary Group 1	0.15/1500 or 0.12/3000* (6.1/140 or 4.9/280)
Ordinary Group 2	0.2/1500 or 0.17/3000* (8.1/140 or 6.9/280)
Extra Group 1	0.3/2500 or 0.28/3000* (12.2/230 or 11.4/280)
Extra Group 2	0.4/2500 or 0.38/3000* (16.3/230 or 15.5/280)

*When required by 19.2.3.1.5.

3. Update the cross reference in paragraph 31.1.1 to read as follows:

31.1.1 Chapter ~~30~~31 outlines the deletions, modifications, and additions that shall be required for marine application. The applicability of Chapter ~~30~~31 shall be determined by the authority having jurisdiction.

Issue Date: August 31, 2021

(Note: For current information about the NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2021 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION