

NFPA 70®-2020 Edition

National Electrical Code®

TIA Log No.: 1597

Reference: Section 706.50

Comment Closing Date: August 30, 2021

Submitter: Laurie B. Florence, UL LLC

www.nfpa.org/70

1. Revise Section 706.50 to read as follows:

706.50 General. All electrical connections to and from the system and system components shall be in accordance with the applicable provisions of this *Code*. ~~Unless otherwise directed by this article, other energy storage technologies~~ The systems shall comply with the ~~applicable provisions of Part III of Article 705~~ Parts I, II, and III of this article.

Substantiation: The reference to Part III of Article 705 is incorrect as there is no Part III in that Article. However, the previous parts of Article 706 apply to these other types of Energy Storage Systems (ESS).

Emergency Nature: The NFPA Standard contains an error or an omission that was overlooked during the regular revision process.

This revision is necessary as the current reference in Section 706.50 is pointing to a non-existent part of Article 705, which could lead to confusion for users of the NEC. Instead, this Section should be pointing to the previous parts of Article 706, which do apply to other types of ESS.