



Tentative Interim Amendment

NFPA[®] 72[®]

National Fire Alarm and Signaling Code[®]

2022 Edition

Reference: A.14.3.2(new) and A.14.4.4.1(new)

TIA 22-1

(SC 21-4-10/ TIA Log #1548)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Add new Annex material A.14.3.2 to read as follows:*

A.14.3.2 In addition to safety considerations, other reasons for delaying fire alarm inspections include nationally or regionally declared disasters, such as pandemics, weather-related emergencies, or other governmentally recognized disruptions.

2. *Add new Annex material A.14.4.4.1 to read as follows:*

A.14.4.4.1 In addition to safety considerations, other reasons for delaying fire alarm testing include nationally or regionally declared disasters, such as pandemics, weather-related emergencies, or other governmentally recognized disruptions.

Issue Date: April 15, 2021

Effective Date: May 5, 2021

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2021 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION