



Tentative Interim Amendment

## NFPA<sup>®</sup> 72<sup>®</sup>

### *National Fire Alarm and Signaling Code<sup>®</sup>*

#### 2022 Edition

**Reference:** 26.2.10(new)  
**TIA 22-2**  
(SC 21-4-11/ TIA Log #1549)

**Note:** Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Add new section 26.2.10 to read as follows:

**26.2.10 Emergency Monitoring Locations.**

**26.2.10.1** Upon an emergency declaration made by a national, state, or local authority that results in a business disruption event that inhibits normal operation of a supervising station, fire alarm system signals shall be permitted to be received at alternate locations other than a listed central station, proprietary supervising station, or remote supervising station.

**26.2.10.2** The provision of 26.2.10.1 shall be permitted to remain in effect for the duration of the emergency declaration.

**26.2.10.3** Specific authorization by local authorities having jurisdiction shall not be required for emergencies declared by a higher authority.

**26.2.10.4** The provision of 26.2.10.1 shall be permitted to remain in place for not more than 30 calendar days following the termination of the declared emergency.

**Issue Date:** April 15, 2021

**Effective Date:** May 5, 2021

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2021 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION