



Tentative Interim Amendment

## NFPA<sup>®</sup> 20

### *Standard for the Installation of Stationary Pumps for Fire Protection*

#### **2022 Edition**

**Reference:** 11.4.1.3.1

**TIA 22-1**

*(SC 21-12-5 / TIA Log #1604)*

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2022 edition. The TIA was processed by the Technical Committee on Fire Pumps, and was issued by the Standards Council on December 8, 2021, with an effective date of December 28, 2021.

*1. Revise 11.4.1.3.1 to read as follows:*

**11.4.1.3.1\*** Fuel supply tank(s) shall be sized for a minimum of 12 hours of engine run time based on the fuel ~~supply~~ consumption rate requirements of the engine as indicated on the manufacturer's published data, plus 5 percent volume for expansion and 5 percent volume for sump.

**Issue Date:** December 8, 2021

**Effective Date:** December 28, 2021

**(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))**

Copyright © 2021 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION