



Tentative Interim Amendment

NFPA[®] 20

Standard for the Installation of Stationary Pumps for Fire Protection

2022 Edition

Reference: 11.4.1.3.1.1
TIA 22-2
(SC 21-12-6 / TIA Log #1611)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2022 edition. The TIA was processed by the Technical Committee on Fire Pumps, and was issued by the Standards Council on December 8, 2021, with an effective date of December 28, 2021.

1. Revise 11.4.1.3.1.1 to read as follows:

11.4.1.3.1.1* When the fuel ~~supply~~ consumption rate requirements of the engine are not known, fuel supply tank(s) shall have a capacity at least equal to 1 gal per hp (5.07 L per kW), plus 5 percent volume for expansion and 5 percent volume for sump.

Issue Date: December 8, 2021

Effective Date: December 28, 2021

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2021 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION