



Tentative Interim Amendment

## NFPA<sup>®</sup> 25

# *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*

**2020 Edition**

**Reference:** 8.3.7.1.3

**TIA 20-1**

(SC 21-12-7 / TIA Log #1603)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2020 edition. The TIA was processed by the Technical Committee on Inspection, Testing, and Maintenance of Water-Based Systems, and was issued by the Standards Council on December 8, 2021, with an effective date of December 28, 2021.

1. Revise 8.3.7.1.3 to read as follows:

**8.3.7.1.3** Where applicable, speed and velocity pressure adjustments shall be applied to the net pressure and flow data obtained to determine compliance with 8.3.7.2.3(~~23~~).

**Issue Date:** December 8, 2021

**Effective Date:** December 28, 2021

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2021 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION