



Tentative Interim Amendment

## NFPA<sup>®</sup> 70<sup>®</sup>

### *National Electrical Code<sup>®</sup>*

#### 2020 Edition

**Reference:** Section 706.50

**TIA 20-14**

*(SC 21-12-11 / TIA Log #1597)*

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70<sup>®</sup>, *National Electrical Code<sup>®</sup>*, 2020 edition. The TIA was processed by the Code-Making Panel 13, and the NEC Correlating Committee, and was issued by the Standards Council on December 8, 2021, with an effective date of December 28, 2021.

*1. Revise Section 706.50 to read as follows:*

**706.50 General.** All electrical connections to and from the system and system components shall be in accordance with the applicable provisions of this *Code*. ~~Unless otherwise directed by this article, other energy storage technologies~~ The systems shall comply with the applicable provisions of Part III of Article 705 Parts I, II, and III of this article.

**Issue Date:** December 8, 2021

**Effective Date:** December 28, 2021

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2021 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION